

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 2020-1055:100

Page 1 of 1

CATEGORY: Acoustical Materials

LISTEE: King & Co., PO Box 10, Clarksville, AR 72830
Contact: BJ Stone *(479) 754-6090 FAX (479) 754-8445

DESIGN: THERMO-TILE. Polystyrene ceiling tile, 12" x 12", 1/2" thick, 1.5 lb./cu. Ft. prepared from FR bead: BF-318 Patterns 1201, 1202, 1205. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:

Flame Spread:	8
Fuel Contributed:	0
Smoke Density:	273

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and FM label.

APPROVAL: Listed as a ceiling tile having Class I flame spread rating. For use as a non-rated interior wall/ceiling finish material when attached with staples to gypsum wallboard backing. Authority having jurisdiction should be consulted prior to installation.

*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager